

NPDES Permit Program Instructions for the Discharge Monitoring Report Forms (DMRs)

Report Year 2004

[REVISED FINAL: DECEMBER 2003]

DMR Instruction Package 2004 For NPDES Permit For states of MA and NH

CONTENTS

Chapter 1

- Instructions for Completing EPA's Pre-printed NPDES Discharge Monitoring Report (DMR) Form 3320-1
- Authorized signature requirements to permit applications and reports from 40 CFR \$122.22

Chapter 2

• Answers to Frequently Asked Questions Regarding DMRs

Chapter 3

• Example DMR Calculations

ATTACHMENTS

Attachment A, Monthly Monitoring Data (Sample)

Attachments B1, B2, B3, B4 (Sample DMRs)

Attachment C, Frequency of Analysis Codes

Attachment C1, Types of Codes (under Limits/Measures)

Attachment D, Sample Types

Attachment D1, Unit of Measure Codes

Attachment E, No Data Indicator Codes (NODI)

Attachment F, Whole Effluent Toxicity Test Summary Sheet [OCTOBER 2000]

Attachment G, The NPDES Whole Effluent Toxicity Testing, Monitoring and Reporting Tips, Common Pitfalls and Guidance [DECEMBER 2001]

Whole Effluent Toxicity Test Certification

Attachment H, Bypass or Sewer Overflow Report Form

THIS ENTIRE INSTRUCTION BOOKLET IS AVAILABLE ON-LINE AT www.epa.gov/REGION01/ENFORCEMENTANDASSISTANCE/ENFDMR.HTML or www.epa.gov/NE/enforcementandassistance/dmr2004.pdf

DMR INSTRUCTION PACKAGE REVISIONS For NPDES Permit(s) for 2004

This page lists any monitoring and reporting procedure and/or requirement that had major changes that may supersede your existing permit. All address changes enclosed supersede the submittal to MA DEP or NH DES or US EPA addresses otherwise written in your NPDES permit.

PLEASE NOTE the following chapter(s), page(s), and section(s) have had minor changes (additions and/or deletions) from the 2003 Instructions:

Chapter 1

Name change: Pretreatment Program: Compliance, <u>Beth Deabay</u>, 617.918.1793

Unit of Measure [see Attachment D1] (page 5, 10,b) added

13. a. (page 7)
 Minor language change -Except for the QA/QC which gets mailed directly to:

New d. SLUDGE - all New England States (page 8)

Chapter 2

New addition to bullets, numbers added to sections:

- 4. <u>If a calendar week begins in one month and ends in the next month, which sample measurements do I report on my DMR?</u>
 Deleted text.
- 6. How and where do I report an error on the DMR? Additional text.
- 7. <u>How and where do I report a sewer overflow or a bypass?</u> Additional text. And new contact information and procedures for MA DEP.

Chapter 3

- 5. <u>Fecal Coliform/Total Coliform/E-coli</u> (page 5) TNTC language changed.
- 9. 10% Fecal Calculations [OCTOBER 1999] (page 6) Added example calculations.

ATTACHMENT D1 - UNIT CODEs - added

THIS ENTIRE INSTRUCTION BOOKLET IS AVAILABLE ON-LINE AT www.epa.gov/REGION01/ENFORCEMENTANDASSISTANCE/ENFDMR.HTML or www.epa.gov/NE/enforcementandassistance/dmr2004.pdf

[FINAL: DECEMBER 2003]

CHAPTER 1. Introduction

INSTRUCTIONS FOR COMPLETING US EPA'S PRE-PRINTED NPDES DISCHARGE MONITORING REPORT (DMR) FORM 3320-1 FOR YOUR NPDES PERMIT

Each month's form should be carefully reviewed to insure entirety of seasonal requirements and specific sampling that might be required less than monthly, i.e. quarterly requirements. After reviewing these DMRs for completeness be sure to read these directions to be certain you understand your reporting obligations.

If your pre-prints include two sets of monitoring requirements to cover different production schemes or climatic considerations for the same discharge point please submit all forms monthly for that discharge point. You should report quantitative data on the appropriate form and merely indicate "NO DATA" on the forms that do not apply for that month. You can do this by using the code "NODI" along with one of the alpha or numeric codes shown on <u>ATTACHMENT E</u> appended to the "Example DMR Calculations".

If toxicity limits are contained in your permit please assure the appropriate data is included on your DMR as well as submitting a copy of the entire laboratory report including chain of custody information to the P.O. Box address listed in this document. Review the 'Toxicity Test Summary Sheet' and 'NPDES Whole Effluent Toxicity Testing, Monitoring and Reporting Tips, Common Pitfalls and Guidance' are included as ATTACHMENT F and G. Although submittal of ATTACHMENT F is not mandatory, we encourage you to use it to ensure that your laboratory utilizes this sheet and that you forward it along with your toxicity report. Utilization of this summary sheet will accelerate the process of reviewing toxicity test reports. However, this sheet is not to be used as a substitute for the actual laboratory report or the DMR.

If sludge limits are contained in your permit please assure the appropriate data is included on your DMR (SL1A - $\underline{\text{ATTACHMENT B-4}}$) as well as submitting a copy of the entire laboratory report including chain of custody information to the P.O. Box address.

Whenever you have an opening in the sample measurement row, whether it be for quantity or concentration, test results must be supplied. If information is not required "******" is printed on the DMR in the permit requirement row as well as in the corresponding measurement row. You <u>must supply</u> the units of measure; the number of exceedances of your permit limit; the frequency with which you've conducted your analyses and the sample type. Please note that even though the permit requirement row indicates some of this information you must verify in the sample measurement row that your testing is being performed in accordance with your permit or enforcement action requirements. If you do additional testing, you need to report it.

You should <u>ignore the column headers</u> of average and maximum on the quantity side and minimum, average and maximum on the concentration side and <u>refer to the reporting requirement</u>

contained in the permit requirement row for each individual parameter. For example if your permit requires you to report a monthly average, weekly average, and maximum day value do not report a minimum value.

CONTACTS for US EPA:

You may contact the **US EPA** Environmental Protection Specialist of the Permit Compliance Staff listed in your annual letter, or additional staff below -

Questions concerning reapplication of a current permit or an application for a new permit:

Massachusetts - Olga Vergara, 617.918.1519 New Hampshire - Shelley Puleo, 617.918.1545

Questions concerning a new permit or an existing permit, and/or modifying an existing permit, contact your Permit Writer as noted in the Fact Sheet issued with your Draft Permit. If you do not know who that may be, you may telephone the following:

617.918.1570, MA Permit Unit 617.918.1580, NH Permit Unit

and you will be directed to the appropriate permit writer.

Other NPDES permit related and/or compliance questions should be directed to the following --

General Permits: Suprokash Sarkar, 617.918.1693

Sludge: permit, Thelma Murphy, 617.918.1615

Whole Effluent Toxicity:

test methods, <u>David McDonald</u>, 617.918.8609 compliance, Joy Hilton, 617.918.1877

permit, <u>Thelma Murphy</u>, 617.918.1615 compliance, <u>Steve Couto</u>, 617.918.1765 Stormwater:

24 hour telephone report to compliance at telephone, $\underline{617.918.1715}$ Bypasses, CSO, DWO:

Pretreatment Program: permit, <u>Jay Pimpare, 617.918.1531</u> compliance, <u>Beth Deabay, 617.918.1793</u>

Questions regarding the QC/QA and US EPA Testing Methods and procedures: contact the $\underline{\text{US}}$ EPA Laboratory in Chelmsford, MA at, $\underline{617.918.8300}$, or, $\underline{978.937.8500}$.

You may contact any **US EPA** employee via E-mail using the following format: last name.first name@epa.gov

For your information and viewing, you may visit the US EPA's WEB SITE at www.epa.gov/enviro or www.epa.gov/region01/ to view any of the EPA programs.

See Chapter 1, Section 13 (pages 6-8) for US EPA, MA DEP, and NH DES addresses and further instructions.

DMR PREPRINTED FORM

1. Permittee Name/Address

Ensure that the correct name and mailing address appears in the top left corner of the form, and the location is correct. If incorrect, submit a letter with the correct information to the address provided in Chapter 1, Pages 6 and 7.

2. Permit Number

Ensure that the pre-printed NPDES Number conforms with the NPDES Number for which you are reporting sample measurement information. REMINDER: **All letters and reports** need the NPDES Number prominently displayed. Submittals for each NPDES permitted facility require a separate cover letter, if one is provided.

3. <u>Discharge Number</u>

A separate DMR form has been **pre-printed for each monitoring period** for each pipe discharge. Check the pre-printed Discharge Number with the Discharge Number for which you are reporting measurement information. A narrative description of the discharge should also appear in the top right corner of the DMR.

4. Monitoring Period

DMR's are normally pre-printed for an entire year. Therefore it is important to check the pre-printed Discharge Number and Monitoring Period against those in your Permit for which you are reporting measurement information. Example: 001A, 001T, 001Q, 002A, SL1A.

5. Parameter

Each parameter contained in your NPDES permit is listed in the far left column of the DMR. Seasonal parameters and pipe discharges are only included on the DMRs for the monitoring periods stipulated in your NPDES permit. Parameters or entire discharge pipes that must be reported less frequently than monthly (i.e. quarterly, semi-annually, etc.) will be included in the DMR's for the last month of the reporting period specified in your NPDES permit. However, sampling for these parameters may be performed any time during the reporting period.

An exception to the above that you may notice in your permit is for either quarterly or semi-annual testing for toxicity. You may have a requirement to test in one month, or a specific day and week, and not be required to submit test results until a later month. For example you could have a quarterly testing requirement of January, April, July and October with submittal required in the months of March, June, September and December. The requirement would be printed on a separate DMR showing a report period in the case of July testing as 00/07/01 to 00/08/31. The PCS system would then expect to see this report submitted within 15 days following the monitoring period end date i.e., for the example above, the report would be due by 00/09/15. Subsequent quarters would be handled the same way in the system. See ATTACHMENT B to "Example DMR Calculations" for Discharge Number 001T.

Particular attention must also be paid to the monitoring location descriptions for each parameter; multiple monitoring locations may appear for the same parameter on a single DMR form.

6. Permit Requirement Row

The Permit Requirement row lists the NPDES permit effluent limit for each parameter and a description of the statistical basis (i.e. minimum monthly, average monthly, maximum daily, etc.) of the reporting requirement. If the parameter is not limited, but monitoring is required, the DMR lists the words "Report" followed by the statistical basis on which the information must be reported. It is imperative to note that the description contained in the Permit Requirement row supersedes the "Average" and "Maximum" quantity headers and the "Minimum", "Average" and "Maximum" concentration headers and the "Minimum", "average" and the permit must be followed (i.e. annual average, monthly average, weekly average, maximum day, minimum, maximum) not the column headings on the DMR form at the top, over the two quantity and the three concentration columns. See ATTACHMENT C1.

If information is not required, then "*****" is printed in the appropriate Permit Requirement blocks as well as corresponding Sample Measurement blocks. In the Permit Requirement row, the Frequency of Analysis, Sample Type, and Units column also reflect the requirements of your NPDES permit. This information must be provided for each parameter to be considered complete, especially if you report in a different measurement.

7. Sample Measurement Row

All blocks within the Sample Measurement row in which "******" does not appear must be used by you to report the information required in the corresponding Permit Requirement row. The accuracy of the reported sample measurements must be consistent with the accuracy of the approved analytical method. Do not leave blank spaces on the DMR unless measurement information is not available for a specific pipe/parameter. If any blanks appear on your DMR, an explanation must be attached to the DMR or shown in the comment field at the bottom of the DMR. EPA's automated violation tracking system will subsequently detect these blanks as non-reporting violations for which you may be subject to enforcement actions.

For those months when no sampling occurs for a specific outfall pipe, write "No DATA" and the NODI code across the DMR, or place the appropriate code in the box in the upper right corner of the DMR. If there is a NODI for a specific parameter, then write NODI and the appropriate code next to or on that line. There is no need to fill in the rest of that row. A copy of the available codes to represent "No Data" is provided in **ATTACHMENT E**.

If all sample analyses for a given parameter were determined to be Below Detectable Limit [BDL], below the minimum level of detection [BMLD], or not detected [ND], a result of 0 (zero) should be reported for that reporting period. In calculating monthly and weekly average values, a 0 (zero) should be

substituted for all results below the minimum level of detection. Report the detected value in the comment section of the DMR; or, report it in a cover letter, if one is provided.

NOTE: Codes of 'B', 'BDL', 'ND', and 'TR' are no longer valid in reporting results that are below the minimum level of detection. Reporting of too numerous to count, TNTC, is to be reported in the daily maximum column. See new language in the EXAMPLE DMR CALCULATIONS, #5. TNTC is converted in PCS as "99999". If the lab reports a trace amount, then reporting of trace amount is to be reported on the DMR as 0 (zero).

Other than the list of valid codes listed on **ATTACHMENT E**, the following are the only symbols other than numerals that can be entered on the DMR form to clarify a numeric result. For example, the symbols "<" [less than] and ">" [greater than] can be used to clarify an analytical result; or the symbol "TNTC" or "T" can be used to indicate a coliform test count that is too numerous to count. If a "T" symbol is used, enter in all measurement boxes for this parameter.

8. No. Ex. (Number of Exceedances)

Enter the number of actual <u>sample measurements</u> that <u>exceeded</u> the <u>permit requirement(s)</u> (maximum and/or minimum, 7-day average, etc.) for each parameter. The number should be the <u>total</u> of all exceedances measured during the reporting period -- both of loading and concentration limits. If all samples measured are at or below the permit level, enter **0** (zero), unless your permit limit has a minimum requirement.

9. Frequency of Analysis

Enter the <u>actual frequency of the sample analysis</u> that occurred during the reporting period in the Sample Measurement row; the minimum frequency is as specified in the corresponding Permit Requirement row. This information must be reported in a compatible format. Therefore, please enter the code that most accurately represents the actual sampling frequency. A copy of the valid codes is provided in **ATTACHMENT C**.

10, a. Sample Type

Enter the actual sample type used during the monitoring period in the Sample Measurement row. Again, the sample type required by your NPDES permit is shown in the corresponding Permit Requirement row. Enter the code that most accurately represents the actual sample type. A copy of the valid codes are provided in **ATTACHMENT D**.

10,b. Unit of Measure Code

Enter the actual unit of measure used during the monitoring period in the Units column. This is important if your laboratory is sampling in different Units. The unit code required by your NPDES permit is shown here. For additional codes, see **ATTACHMENT D1** which has been added to these instructions.

11. Comments

Please take note of any pre-printed comments or instructions that appear on the bottom of the DMR form(s). This field should also be used to reference any required explanations of permit violations and should also note the persons or laboratory that performed the analytical work. If there is not enough space available to explain violations you must attach an explanation to the DMR. This can be handled through your transmittal letter.

12. Signature

Be sure the name and title of the principal executive officer or his/her authorized agent is provided and that the form is appropriately signed and dated. AN ORIGINAL DMR FORM AND SIGNATURE IS REQUIRED (do not send in the duplicate carbonless DMRs, nor a photocopy of the original). If an authorized agent is signing the DMR, a written authorization must be provided to EPA. Should a duly authorized agent sign and certify the DMR form, a written authorization must be submitted to the Agency in accordance with 40 CFR \$122.22(b)(1), (2), and (3). Any change to an authorization must be submitted in writing in accordance with 40 CFR \$122.22(c). All certifications must be in accordance with 40 CFR \$122.22(d). Following this chapter is a copy of \$122.22 [40 CFR Ch.1 (7-1-99 Edition)].

13. Transmittal

a. To the US EPA:

All reports should be forwarded in time to reach the **US EPA** by the date specified in your permit and should be mailed to the P.O. Box address:

Water Technical Unit (SEW)
U.S. ENVIRONMENTAL PROTECTION AGENCY
P.O. BOX 8127
BOSTON, MA 02114

Except for the QA/QC, which should be mailed directly to:

US EPA - New England Regional Laboratory
11 Technology Drive
Chelmsford, MA 01863-2431

b. To the NH DES:

For the State of New Hampshire, submit a copy of your DMR to the:

New Hampshire Department of Environmental Services (NH DES)
Water Division
Wastewater Engineering Bureau
6 Hazen Drive, P.O. Box 95
Concord, NH 03302-0095

C. To the Massachusetts Department of Environmental Protection (MA DEP):

For the State of Massachusetts, submit a copy of your DMR and all other notifications including overflow or bypass reports, but excluding toxicity test reports, to your local regional office listed below: [NOTE: add address line 2 for - Bureau of Resource Protection (POTWs), or Bureau of Waste Prevention (Industrial Dischargers, others)

MA DEP

MA DEP

Central Regional Office 627 Main Street Worcester, MA 01608 Southeast Regional Office 20 Riverside Drive Lakeville, MA 02347

MA DEP Northeast Regional Office (Boston) One Winter Street Boston, MA 02108

MA DEP Western Regional Office 436 Dwight Street Suite 402 Springfield, MA 01003

If you are not sure which Massachusetts DEP Regional Office oversees your facility, go to:
 http://www.state.ma.us/dep/cities.htm

NOTE: Submit Whole Effluent Toxicity tests, as well as an additional copy of DMR's and related notices to:

Massachusetts Department of Environmental Protection (MA DEP)
Division of Watershed Management (DWM)
627 Main Street, 2nd Floor
Worcester, MA 01608

MA DEP contacts:

If you are seeking information about DEP permitting, need application forms, or have questions about annual compliance fees, call the MA DEP Regional Service Center:

Central Region (Worcester)	508-792-7683
Northeast Region (Boston)	617-654-6500
Southeast Region (Lakeville)	508-946-2714
Western Region (Springfield)	413-784-1100 x214

If you are reporting an overflow, bypass, or back up, (not including CSO's), provide immediate telephone notification during normal business hours to the appropriate MA DEP Regional Office at these numbers:

Central Region (Worcester)	508-792-7650
Northeast Řegion (Boston)	617-654-6506
Southeast Region (Lakeville)	508-946-2750
Western Region (Springfield)	413-784-1100

If you believe an overflow, bypass, or any other discharge may have resulted in an oil or hazardous material release, report it to MA DEP at any time, 24 hours a day, at this $toll\ free\ number:\ 1-888-304-1133$.

In addition, the MA DEP anticipates that electronic reporting of an overflow, bypass or other discharge will be available in early 2004. Please check the MA DEP website for details and the availability of this service: http://www.state.ma.us/dep

For general information about MA DEP permitting, call the MA DEP InfoLine:

617-338-2255 (From area code 617 and outside MA) 800-462-0444 (From area codes 413, 508, 781, and 978)

For information on WWTF operator certification and training, or information about residuals management, contact the Millbury Training Center:

WWTF Operator Certification 508-756-2214 Residuals (Sludge) Management 508-752-8648

For information about MA DEP grant and loan programs, call the Division of Municipal Services at 617-292-5793

Permit applications, publications, and compliance information are also available at the MA DEP website: http://www.state.ma.us/dep/

d. SLUDGE - all New England States:

All the following sludge/POTW permittees in the States of: Connecticut, Massachusetts, Maine, New Hampshire, Rhode Island, and Vermont, submit your annual Sludge [Section 503 Regulations] reports to the US EPA at the P.O.Box 8127 address (above) by February 19 each year. If your permitted facility had DMR forms mailed to you, submit those with your annual report.

***** This version *FINAL: December 2003* supersedes the contact address and submittal information to your State or the US EPA address(es) otherwise written in your NPDES permit, and/or enforcement order. *****

Signature Requirements

[Code of Federal Regulations] [Title 40, Volume 14, Parts 87 to 135] [Revised as of July 1, 1999] From the U.S. Government Printing Office via GPO Access [CITE: 40CFR122.22]

[Page 745-746]

PART 122--EPA ADMINISTERED PERMIT PROGRAMS: THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM--Table of Contents

Subpart B--Permit Application and Special NPDES Program Requirements

Sec. 122.22 Signatories to permit applications and reports (applicable to State programs, see Sec. 123.25).

- (a) Applications. All permit applications shall be signed as follows:
- (1) For a corporation. By a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities employing more than 250 persons or having gross annual sales or expenditures exceeding \$25 million (in second-quarter 1980 dollars), if authority to sign documents has been assigned or delegated to the manager in accordance with

corporate procedures.

Note: EPA does not require specific assignments or delegations of authority to responsible corporate officers identified in Sec. 122.22(a)(1)(i). The Agency will presume that these responsible corporate officers have the requisite authority to sign permit applications unless the corporation has notified the Director to the contrary. Corporate procedures governing authority to sign permit applications may provide for assignment or delegation to applicable corporate positions under

Sec. 122.22(a)(1)(ii) rather than to specific individuals.
(2) For a partnership or sole proprietorship. By a general

partner or the proprietor, respectively; or
(3) For a municipality, State, Federal, or other public agency. By either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes: (i) The chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geograph (EDA) Administrators of EPA).

(b) All reports required by permits, and other information requested by the Director shall be signed by a person described in paragraph (a) of this section, or by a duly authorized representative of that person. A person is a duly authorized

representative only if:

(1) The authorization is made in writing by a person

described in paragraph (a) of this section;

(2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company, (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) and,

(3) The written authorization is submitted to the Director.
(c) Changes to authorization. If an authorization under paragraph (b) of this section is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph (b) of this section must be submitted to the Director prior to or together with any reports, information, or applications to be signed by an reports, information, or applications to be signed by an authorized representative.

(d) Certification. Any person signing a document under paragraph (a) or (b) of this section shall make the following

certification:

I certify under penalty of law that this document and all ATTACHMENTs were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and

[[Page 746]]

complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

(Clean Water Act (33 U.S.C. 1251 et seq.), Safe Drinking Water Act (42 U.S.C. 300f et seq.), Clean Air Act (42 U.S.C. 7401 et seq.), Resource Conservation and Recovery Act (42 U.S.C. 6901 et seq.))

[48 FR 14153, Apr. 1, 1983, as amended at 48 FR 39619, Sept. 1, 1983; 49 FR 38047, Sept. 29, 1984; 50 FR 6941, Feb. 19, 1985; 55 FR 48063, Nov. 16, 1990]

[FINAL: DECEMBER 2003]

CHAPTER 2. ANSWERS TO FREQUENTLY ASKED QUESTIONS for DMRs

1. Who do I contact at the US EPA if there are any discrepancies between my NPDES permit and the preprinted DMR Forms?

If there are any discrepancies, or you have questions, between your permit and the DMR form, please call the Environmental Protection Specialist named in your annual transmittal letter or write to:

Water Technical Unit (SEW)
U.S. ENVIRONMENTAL PROTECTION AGENCY
P.O. BOX 8127
BOSTON, MA 02114

NOTE: The permittee is required to sample and report in accordance with your NPDES Permit or your current enforcement action, if applicable. Errors or omissions on the preprinted DMR forms do not preclude any reporting requirement you may have. If there are errors, contact your Environmental Protection Specialist.

2. What analytical procedures do I use?

Sampling and analytical procedures must comply with 40 CFR §136. [See EPA's home page on the WEB at www.epa.gov/ and click on LAWS & REGULATIONS, or go directly to www.access.gpo.gov/nara/cfr/index.html. The procedures are basically the same as those in Standard Methods For The Examination of Water And Wastewater. However, not all Standard Methods procedures are approved for EPA use. To ensure that your analytical procedures meet EPA requirements, please check the cited EPA regulations. In addition, the name of the persons or laboratory performing the analytical work must be provided in any available space in the comments section that appears on the bottom of the form. If there is no space available on the DMR, include this information in a cover letter.

3. Can any symbols other than numerals be entered on the DMR?

Other than the list of valid codes listed on **ATTACHMENT E**, the following are the only symbols other than numerals that can be entered on the DMR form to clarify a numeric result. For example, the symbols "<" [less than] and ">" [greater than] can be used to clarify an analytical result; or the symbol "TNTC" can be used to indicate a coliform test count that is too numerous to count.

4. If a calendar week begins in one month and ends in the next month, which sample measurements do I report on my DMR?

All sample measurements must be reported on the DMR for the \mathbf{month} in which the samples were taken. The exception occurs when a calendar week begins in one month and ends in the next. In this instance, compliance with \mathbf{weekly} reporting requirements must be reported for the month in \mathbf{which} the calendar week ends.

5. What results do I report if I sample more frequently than required by my NPDES Permit?

All monitoring requirements of the NPDES permit are <u>minimum</u> requirements. The results of any <u>additional</u> monitoring of parameters at location(s) designated in the NPDES Permit, using approved sampling procedures and analytical methods, must be included in the DMR calculations. Such increases in the frequency of sampling must also be reported in the Frequency of Analysis block. [40 CRF §122.41(1)(4)]

6. How and where do I report an error on the DMR?

To correct an error in reporting data on the DMR, or you need to make a change due to an error in reporting, cross out the value(s), reenter and initial the field/box. Any errors in reporting need to be noted, either on the bottom of the DMR or in a cover letter. Please contact the Environmental Protection Specialist mentioned in your annual DMR letter. Always keep the permit, fact sheet, the annual letter, and these instructions together.

7. How and where do I report a sewer overflow or a bypass?

Please review the document that came with your permit entitled Contents - Part II (September 1, 1993) [latest version]. Especially read Section B. 4. Bypass; and, Section D. 1. e. You will find the attached form useful in fulfilling your reporting responsibility. You may copy it and/or add your official heading to this form. See ATTACHMENT H: Bypass or Sewer Overflow Report.

For reporting in Massachusetts:

If you believe the overflow, bypass, or any other discharge may have resulted in an oil or hazardous material release, report it to MA DEP at any time, 24 hours a day, at this toll free number: 1-888-304-1133.

Provide immediate telephone notification during normal business hours of any overflow, bypass, or back up (not including CSO's), to the appropriate MA DEP Regional Office at the telephone number provided above in Chapter 1. Section 13. Transmittal c. To the MA DEP.

Provide a written submission within five (5) days of the time you become aware of the circumstances. The written submission shall contain a description of the non-compliance, including exact dates and times, and if the non-compliance has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent reoccurrence of the non-compliance. Mail written submissions within five (5) days to the EPA address and the appropriate MA DEP Regional Office addresses provided above in Chapter 1. Section 13. Transmittal c. To the MA DEP.

The MA DEP accepts EPA's ATTACHMENT H or you may use the Massachusetts DEP Emergency Overflow/Bypass Notification Form which can be downloaded at: http://www.state.ma.us/dep/brp/npdes/surffms.htm

In addition, the MA DEP anticipates that electronic reporting of an overflow, bypass or other discharge will be available in early 2004. Please check the MA DEP website for details and the availability of this service: $\frac{\text{http://www.state.ma.us/dep}}{\text{http://www.state.ma.us/dep}}$

8. To whom do I submit the completed DMR form?

Please complete the DMR in accordance with the attached instructions, have each page of the DMR signed and dated by the principal executive officer or authorized agent and return the signed original DMR to the responsible regulatory agency. The responsible regulatory agency is the US EPA, unless the NPDES permit compliance program has been delegated to a state agency.

You will note that in addition to the original top page, triplicate copies of the DMR have been provided on contact paper. For permittees in the States of **Massachusetts** and **New Hampshire**, one copy of the signed DMR should be retained in your files and another mailed to the State regulatory agency; in MA, a copy must also be sent to DWM. The original, signed, and dated DMR should be forwarded to the US EPA.

All New England States with SLUDGE reporting requirements, and for the states of MA and NH for all NPDES Permit and Special General Permit requirements/reporting need to be mailed to the following **US EPA** mailing address:

Water Technical Unit (SEW)
U.S. ENVIRONMENTAL PROTECTION AGENCY
P.O. BOX 8127
BOSTON, MA 02114

[FINAL: DECEMBER 2003]

CHAPTER 3. EXAMPLE DMR CALCULATIONS

Sampling information for a typical municipal wastewater treatment plant is provided in $\operatorname{ATTACHMENT} A$. The resultant Discharge Monitoring Report (DMR) reflecting this information appears as $\operatorname{ATTACHMENT} B$. A sample DMR for Whole Effluent Toxicity monitoring is also included as part of $\operatorname{ATTACHMENT} B$ (also see $\operatorname{ATTACHMENTS} F$ and G). This illustrates the footnote that specifies the Permit requirements.

The following is an explanation of the derivation of the numbers that appear on the completed DMR. These examples can be applied to calculating: Monthly Average, Weekly Average, Daily Maximum. For these examples, we have used BOD and TSS.

1. Five-day Biochemical Oxygen Demand (BOD_5) and Total Suspended Solids (TSS)

a. Concentration Block Data Entry

Table 1 in **ATTACHMENT A** lists nine effluent BOD $_5$ sample results for the month. The reported values are 40.0, 19.1. 6.2, 10.3, 10.2, 12.0, 7.1, 10.1, and 45.6 mg/L. The monthly average concentration 17.8 mg/L was determined by adding these nine values and dividing by the number of samples. The weekly average concentration represents the highest average of daily discharges over a calendar week. For DMR reporting purposes, a calendar week runs from Sunday through Saturday, inclusive. In the specific instance where a calendar week begins in one month and ends in the next, compliance with weekly reporting requirements should be reported on the DMR in which the calendar week ends.

Weekly averages are calculated by taking the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week. In the specific example, the weekly BOD_5 averages were calculated as follows:

 Period	Calculation	Weekly Average(mg/L)	Monthly Average
1/1-1/7	<u>40.0+19.1</u> 2	29.6	
1/8-1/14	6 .2+10.3	8.3	
1/15-1/21	<u>10.2+12.0</u> 2	11.1	
1/22-1/28	7.1+10.1	8.6	17.8

Therefore, the highest average weekly concentration was 29.6 mg/L. (Note that the weekly average concentration for the calendar week beginning 1/29 has not been calculated for the January, DMR. This calculation would be reported in the month in which the calendar week ends - February.) Subsequently, a monthly average concentration of 17.8 mg/L, a weekly average concentration of 29.6 mg/L (1/1-1/7), and a maximum daily concentration of 45.6 mg/L (1/30) have been reported in the respective Sample Measurement blocks. Influent BOD,

concentrations and influent and effluent TSS concentrations were similarly calculated. (Note that this is an example of when the description contained in the Permit Requirement row supercedes the column header of the DMR.)

<u>Quantity or Loading Block Entry</u>

The "average monthly loading" is calculated by dividing the total of the daily loads, as derived from each day's calculated measurement, by the number of days during the month the measurements were made. In completing calculations for these averages, quantities or loadings are to be reported in lbs/day or kg/day (depending on the unit requirement stipulated in the Permit Requirement block) using the following equations:

In our specific example; the NPDES permit requires that quantities be monitored and reported in lbs/day (see units column under "Quantity or Loading" header)

[conc. = concentration ; conv. = conversion factor]

Effluent 5-Day Biochemical Oxygen Demand (BOD_5)

Date	Flow(MGD)	$x BOD_{5} (mg/L)$	x 8.34 =	Quantity(lbs/day)
1/3 1/4 1/9 1/10 1/18 1/19 1/22 1/23 1/30	.33 .33 .47 .42 .60 .46 .52 .40	40.0 9.1 6.2 10.3 10.2 12.0 7.1 10.1 45.6	8.34 8.34 8.34 8.34 8.34 8.34 8.34 Total:	110.09 52.57 24.30 36.08 51.04 46.04 30.79 33.69 171.14 555.74

The monthly average effluent loading was then calculated by dividing the total monthly loading by the number of sample measurements taken during the month:

Monthly avg. =
$$\frac{\text{Total Monthly Loading}}{\text{No. of Sample Measurements}}$$

= $\frac{555.74}{9}$ = 61.75 lbs / day

Subsequently, the monthly average and maximum daily BOD $_5$ effluent loadings have been reported as 61.75 lbs/day and 171.14 lbs/day (1/30), respectively. Influent BOD $_5$ and influent and effluent TSS loadings were similarly calculated.

c. <u>Daily</u>

Maximum daily discharge limitation means the highest allowable "daily discharge". Daily discharge means the "discharge of a pollutant" measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharge over the day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the day. [40 CFR §122.2]

d. <u>Exceedances</u>

The total number of exceedances (permit conditions exceeded) for the monthly and weekly average and daily maximum loadings must be entered in the "No. Ex." Block. In the sample illustration, there were no exceedances of either the permit concentration limits or permit quantity limits. Therefore, the total number of exceedances was reported as "0".

e. <u>Sampling Frequency</u>

The example facility is required to take BOD_5 samples twice per week whereas the required sampling frequency for Total Suspended Solids is once per week. While this might be an unusual situation, we have used this example to illustrate different frequency of analysis computer codes. Note: **ATTACHMENT C** - Frequency of Analysis Code Table indicates the PCS code for twice/week sampling of 02/07, and once/week sampling of 01/07, respectively. ATTACHMENT C lists the only valid codes for reporting frequency of analysis.

f. <u>Sample</u>

Composite-Samples were taken for BOD_5 and TSS. **ATTACHMENT D,** Sample Type indicates the computer code for composite sampling to be "CP", or, 24-hour composite would be "24".

2. pH

NPDES permit limits for pH are listed in the Permit Requirement row. For the specific example, the Permit Requirement row established minimum and maximum allowable pH limits. In the example data in **ATTACHMENT A**, the pH measurement data indicated a minimum pH of 6.26 and a maximum pH of 8.33. The number of Exceedances was three (two exceedances of the minimum limit - 1/11 & 1/12 plus one exceedance of the maximum limit - 1/4). The Frequency of Analysis was daily (01/01) and the Sample Type was grab (GR).

3. Flow

The DMR indicates that the NPDES Permit limit for the monthly average flow is 2.0 MGD, and requires that the maximum daily flow be monitored and reported in MGD. The monthly average flow from the sample illustration, **ATTACHMENT A** was computed to be 0.44 MGD. The daily maximum flow is the highest daily flow observed during the monthly reporting period while the minimum

is the lowest. The maximum flow of 0.64 MGD occurred on 1/29 and the minimum flow of 0.25 MGD occurred on 1/7. The total number of exceedances (permit conditions exceeded) for only the average flow (the maximum flow is not limited) must be entered in the "No. EX" block on the report. In the specific example, this number was "0". The Frequency of Analysis was continuous (99/99) and the sample type was recorder (RC).

NEW PERMIT FLOW LANGUAGE for Massachusetts municipal and privately owned sanitary wastewater facilities (e.g. condominiums, nursing homes) with permits issued since 2001:

If your flow is an annual average limit, report maximum and minimum daily rates and total flow for each operating date. This is an annual average limit, which shall be reported as a rolling average. The first value will be calculated using the monthly average flow for the first full month ending after the effective date of the permit and the eleven previous monthly average flows. Each subsequent month's DMR will report the annual average flow that is calculated from that month and the previous 11 months.

4. Total Chlorine Residual

The NPDES permit limits the maximum total chlorine residual concentration to 0.05 mg/L. **ATTACHMENT A** indicates that the maximum total chlorine residual was 0.3 mg/L. The Total number of reported exceedances was four, which was entirely comprised of violations of the maximum permit limit $(1/8,\ 1/10,\ 1/23,\ 1/24)$. Sampling type was grab (GR).

EXAMPLE FOR YOUR INFORMATION: If the parameter is sampled more than once per day, the daily maximum would be the highest sample day, averaged.

5. Fecal Coliform/Total Coliform/E-coli

The permit Requirement row requires the calculation of monthly and weekly geometric means. These calculations are best performed using a hand calculator with at least one memory and log function key. Add the logarithms of the sample measurements taken during the statistical basis period (weekly, or monthly), divide the total by the number of sample measurements and take the antilog of the result to determine the geometric mean. For example, the monthly geometric mean of fecal coliform measurements in the example was calculated as follows:

```
\log(240) + \log(140) + \log(80) + \log(1000) + \log(50))/5 =
(2.3802 + 2.1461 + 1.9031 + 3.000 + 1.6990)/5 = 2.2257
antilog (2.2257) = 168
```

What happens when there is a zero (0)? You must add '1' (one) to each of the results and then subtract '1' from the answer (also below).

EXAMPLE:

Geometric mean calculation without correction:

	Mon	Wed	Fri	Weekly GM	MonthlyG M
Week 1	41	34	29	34.3	
Week 2	27	39	0	ERR	
Week 3	0	56	18	ERR	
Week 4	51	37	29	38.0	ERR
				Limit=50	Limit=15

Geometric mean calculation with correction:

Adding '1' to each value and subtracting '1' from the result

		Mon	Wed	Fri	Weekly GM	Monthly GM
Week	1	42	35	30	34.3	
Week	2	28	40	1	9.4	
Week	3	1	57	19	9.3	
Week	4	52	38	30	38.0	18.6
					Limit=50	Limit=15

SAMPLE of WEEK 1

Geometric mean of 41, 34, 29 = 34.3Geometric mean of 42, 35, 30 = 35.3; 35.3 - 1 = 34.3

SAMPLE of WEEK 2

Geometric mean of 27, 39, 0 = ERRORGeometric mean of 28, 40, 1 = 10.4; 10.4 - 1 = 9.4

TNTC: If you have a value that is too numerous to count 'TNTC', write 'TNTC' or 'T' in the daily maximum block, record the exceedance(s), in the No.Ex. block. To calculate the GEO Means, discard the TNTC value(s) and use only the valid test results to calculate the monthly and weekly GEO Means. (This technique will result in an underestimation of the weekly and monthly geometric means.) Submit the number of TNTC for the month, including the dilutions used in each test, and how it was resolved. If additional monitoring was taken, report it in the Frequency of Analysis block.

6. BOD, and TSS Percent Removal Calculations

% removal calculations must be performed using the following formula:

Monthly Average Influent TSS Concentration = 177.0 Monthly Average Effluent TSS Concentration = 14.5

% Removal TSS =
$$\frac{177.0 - 14.5}{177.0} *100 = 91.8\%$$

It should be noted that the monthly average percent removal **is not** calculated by averaging the daily percent removal values. Instead, the monthly average percent (%) removal is calculated from two numbers; the average influent concentration and the average effluent concentration for that month.

7. No Analytical Result

Although not displayed on the sample DMR, the situation may occur where no analytical result can be reported. Refer to **ATTACHMENT E** for a listing of acceptable <u>No Data Indicator</u> (NODI) codes. Enter the code anywhere on the report/parameter line and do not fill in anything else.

8. Toxicity Reporting

We encourage your use of **ATTACHMENT F**, the Toxicity Test Summary Sheet. This sheet should be filled out by your biomonitoring laboratory and forwarded along with your complete Whole Effluent Toxicity lab report. Completion of this sheet will facilitate the review of biomonitoring data. Test results should also be included on your DMR, where applicable, i.e. 001T. See **ATTACHMENT F and G**.

9. 10% Fecal Calculations [OCTOBER 1999]

You may have had your NPDES permit written to include this language:

Additional information to help explain the reporting requirement of the "10%" language in NPDES Permits.

Violation of "Percent of values >400 CFU" No violation of monthly average

							Percent values
	Mon	Tue	Wed	Thu	Fri	Monthly GM	> 400
Week 1	156	<u>411</u>	<u>509</u>	187	189		
Week 2	145	123	88	90	125		
Week 3	121	137	<u>729</u>	<u>633</u>	<u>841</u>		
Week 4	105	98	90	93	90		
Week 5	88	88				166.9	<u>23%</u>
						Limit=200	Limit=10%
iolation of mon		s >400 CFU"					
	Percent of value						Percent values
		s >400 CFU" Tue	Wed	Thu	Fri	Monthly GM	Percent values > 400
	Percent of value	Tue	Wed 898	Thu 394	Fri 389	Monthly GM	
o violation of "	Percent of value Mon					Monthly GM	
o violation of ". Week 1	Percent of value Mon 196	Tue <u>691</u>	898	394	389	Monthly GM	
o violation of " Week 1 Week 2	Percent of value Mon 196 195	Tue <u>691</u> 188	898 189	394 193	389 185	Monthly GM	
Week 1 Week 2 Week 3	Percent of value Mon 196 195 197	Tue 691 188 366	898 189 371	394 193 287	389 185 187	Monthly GM 241.9	

ATTACHMENT A

Monthly Monitoring Data (Sample) January, 2000

			Flow	\underline{BOD}_5		<u>TSS</u>		<u>Hq</u>	CL	<u>SS</u>	<u>Fecal</u>
1 st 1 2 3 4 5 6 7	Week Sun Mon Tue Wed Thu Fri Sat	Date 1/1 1/1 1/3 1/4 1/5 1/6 1/7	.50 .32 .33 .33 .43 .34	192.2 212.0	E 40.0 19.1	I 185.	E 4	7.31 7.78 34.0 6.81 7.24 7.45	BDL 8.33 BDL BDL	0.1 7.46 BDL 0.0	.240 BDL0.2
2 nd 8 9 10 11 12 13 14	Week Sun Mon Tue Wed Thu Fri Sat	1/8 1/9 1/10 1/11 1/12 1/13 1/14	.58 .47 .42 .37 .46 .32	186.1 200.3	6.2	163.	1	7.61 3.3 6.26 6.49 7.07 7.08	BDL BDL	0.1 7.42 0.06 0.1	
3 rd 15 16 17 18 19 20 21	Week Sun Mon Tue Wed Thu Fri Sat	1/15 1/16 1/17 1/18 1/19 1/20 1/21	.62 .61 .60 .46	206.1 183.0	10.2 12.0	187.	0		BDL BDL 6.84 BDL	0.1 0.1 7.30 BDL	80 BDL 0.4
4 th 22 23 24 25 26 27 28	Week Sun Mon Tue Wed Thu Fri Sat	1/22 1/23 1/24 1/25 1/26 1/27 1/28	.42 .52 .40 .38 .45 .42	187.2 194.1	7.1 10.1	172.	5		6.88 7.27 BDL BDL BDL	0.08 0.3 0.0	1000
5 th 29 30 31	<u>Week</u> Sun Mon Tue	1/29 1/30 1/31	.64 .45 .44	215.0	45.6			6.85 6.89	7.24	0.1 BDL 0.1	50

I - Designates Influent
E- Designates Effluent
BDL - Designates a '0' (zero) calculation

 $[\]ensuremath{^{\star}}\xspace$ Note: BDL is not to be reported on DMR, check your permit for any ML (minimum level of detection) requirements.

DAY

QM

YEAR

NUMBER

AREA

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

4 my

CONTROLLED TO THE CONTROLLED THE CONTROLLED TO THE CONTROLLED TO THE CONTROLLED T

02

978 123-4567 00

NOTE: Read Instructions before completing this form FREALEN SANTARY WASTEWATER Check here if No Discharge DAILY MX **** 水水水水水水 8 SAXTMIN 水水水水水水 长女女女女女 DATEN MX MAXIMUM OUALITY OR CONCENTRATION (48-83) (54-61) 45.6 8.33 34.0 0.4 SUBR E) 50 水水水水水水 **** AVERAGE REPORT REPORT MO AVG 177.0 001А овремияем (28-27) (28-29) (30-31 197.3 DISCHARGE MONITORING REPORT (DMR)
01SCHARGE MONITORING REPORT (DMR)
02-16 YEAR | MO | DAY 29.6 34.0 WKLY 0.2 45 00 01 安全安全安全 水水水水水水 **** MONITORING PERIOD MO AVG ****** 水水水水水水 MINIMUM MD AVG (4 Card Only) (38-45) 17.8 6.26 2 30 6.5 30 (20-21) (22-23) (24-25) YEAR MO DAY 1529 dy PERMIT NUMBER LBS/DY LBS/DY T.RS/DY 1bs/dy LBS/DY bs/dy STINO 26) 26) (26) ** MA0100006 QUANTITY OR LOADING DATLY MY 宋京京安安北 我我我我我我 DAILY MX **** 化化化水水水 有衣衣衣衣衣 水水水水水水水 我我我我我敢 FROM 00 REPORT MAXIMUM REPORT (24-61) 171.14 93.57 水水水水水水 水水水水水水水 水水水水水水 REPORT MO AVG NO AVET AVERAGE 727.02 51.44 708.36 (46-53) 02116 (3 Card Only) 61.75 XYZ W W T P. Newton, MA 02116 Mr. JOHN SMITH, SUPERINTENDENT AVG OW. PERMITTEE NAME/ADDRESS (INSULA FACIN) NAME XYZ WASTEWATER TREATEMENT PLANT 500 500 MG MA SAMPLE SAMPLE SAMPLE MEASUREMENT MEASUREMENT PERMIT REQUIREMENT SAMPLE SAMPLE MEASUREMENT PERMIT REQUIREMENT RECUREMENT REQUIREMENT STREET GOROSS VALUE EFFLUENT GROSS VALUE VALUE SETTLEABLE 123 CENTER RAW SEW/INFLUENT RAW SEW/INFLUENT 0 SUSPENDED EPFIBENT GROSS 6 PARAMETER (32-37) NEWTON (20 DEG. SOLIDS, TOTAL TOTAL 20 DEG. 5-DAY 5-DAY SUSPENDED EPPLBENT SOLIDS. SOLIDS, FACILITY ADDRESS ATTEN: BOD, H

TWICE COMPO

MG/L

CP

02/07

0

19)

(89-70)

ANALYSIS (84-68)

(09-00) SE.

UNITS

Form Approved. OMB No. 2040-0004 Approval expires 05-31-98

Attachment B-1

COMPOS

/器型

MG/L

CB

02/07

0

(13) mg/1

GRAB

DAILY

E

01/01

12)

SU S COMPOS

TWICE WEEK

B

02/07

c

(13) mg/1

COMPOS

過過

MG/T

9

02/07

o

19 mg/1

MG/L

GRAB

DAILT

ML/I

DAILY MC

ONRLY AVE

水水水水水水

水水水水水水

水水水水水水

050

MGD

99.0

0.44

MEASUREMENT

IN CONDUIT OR

FLOW.

THRU TREATMENT PLANT

50050

DALLY MX MGD

MG AVG

REQUIREMENT

EFFLUENT GROSS VALUE REJUNE
NAME/TILLE PRINCIPAL EXECUTIVE OFFICER

John Smith, Superintendent

TYPED OR PRINTED

PERMIT

**

水水去水水水

水水水水水水

REQUIREMENT

GROSS

EFFLUENT

00545

03/07

(1,75)

CONTINUE

**

水水水水水水

化水水水水水

DATE

TELEPHONE

RC

99/99

o

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

WHOLE EFFLUENT TOXICITY: ON DMR 0011. EACH OFRATING DAY. FOR TOTAL FLOW RATES + MAXIUMU REPORT

EPA Form 3320-1 (10-96)

MONITORING PERIOD 02116 FROM OU DAY SMITH SUPERINTENDENT (20-21) (22-25) (24-25) MA0100006 PERMITTEE NAME/ADDRESS (Notate Facility Name/Location # Distance
NAME XYZ WASTEWATER TREATMENT PLANT ADDRESS 123 Center Street 02116 Newton, MA 02116 XYZ W W T P Newton, MA ATTN: JOHN FACILITY

NATIONAL POLLUTANT DISCHARGE ELABARTION SYSTEM (MPGES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) DISCHARGE NUMBER PERMIT NUMBER

MINOR ATTACHMENT B-2 (SUBR E) F-FINAL TREATED SANITARY WASTEWATER

Chack here if No Discharge

NOTE: Read Instructions before completing this form

(26-27) (28-29) (30-31)

00 h1

2

YEAR MO DAY

FREQUENCY SAMPLE	(64-68) (89-70)	/01 GR	ILY GRAB	01/07 GR	WEEKLY GRAB	01/30 CA	ONCE/CALCTO RONTH	01/30 CA	ONSE GALCTO							DATE	100	4-
-		01	DA		184		NO MO	_	-								6	1
NO.	UNITS (ISS-60)	(19) 4	MG/L	-	#/.100m	(23) 0	ERCENT	(23) 0	PERCHNT							TELEPHONE	978 123	7
TRATION (54-61)	MAXIMUM	8.3	MAKIMUM	1000	400 411.7 MX	****	****	***	****								T	XECUTIVE
QUALITY OR CONCENTRATION (46-53) (54-61)	AVERAGE	****	****	1000	400	*	****	****	*****								of the	PSIGNATURE OF PRINCIPAL EXECUTIVE
(4 Card Only) QU/ (38-45)	MINIMUM	****	*****	168	200 MO GEO		85 No AVG	1	85 MG AVG				7			GB/M/Bey O		
	UNITS		* *	* * *	**		**	*	* * *	K K						TACS-MBITS WERE SYSTEM DESIGNATION	NAME AND PARTIES AND THE SAME A	the include from its in
QUANTITY OR LOADING (54-61)	MAXIMUM	* * * *	* 在大大大大大大大大大	****	****	***	***	* * * *	****							THE DOCUMENT AND ALLY	CONTRIBUTE DISALLISTE NO CONTRIBUTE MAD	office order frame statistics in
(3 Card Only) QUA (48-53)	AVERAGE	***	*****	***	****	*****	*****	***	***							SOUTH PRINCETY OF LAW THAT	Superior of the properties of	TAND STUDIES A COST PAR
>	7	SAMPLE MEASUREMENT	PERMIT	SAMPLE	PERMIT PERMIT	PERCENT SAMPLE	PERMIT	SAMPLE	PERMIT	SAMPLE MEASUPEMENT	PERMIT	SAMPLE	PEHMIT	SAMPLE	PERMIT	DEFICER CONTRACT	ntendering	C405 4 mg
PARAMETER APS 3T	(ne.n)	INE	EFFLUENT GROSS VALUESUMENT	-	74055 1 0 0	DAY	O K	X.	PERCENT REMOVAL	PERCENTREMOVAL						NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	John:Smith, Superi	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Parterence all attachments bere)
SEE PERMIT FOR ADDITIONAL MONITORING AND REPORTING REQUIREMENTS.

ANY OTHER ATTACHMENTS

AND

CONDITIONS

EPA Form 3320-1 (10-96)

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

TO YOUR PERMIT.

6

ALSO REFER TO THE GENERAL PERMIT

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

NATIONAL POLLITANT DISCHARGE ELANNATION SYSTEM (APPER)
DISCHARGE MONITORING REPORT (DMR)
(17.18) MAOIGGOUG

PERMITTEE NAME/ADDRESS (water facility Name/Location #Diffusion)
NAME XYZ W W T P

ADDRESS 123 Center Street

Newton

PERMIT NUMBER

RFFLUENT

MONITORING PERIOD

DAY

YEAR

NO DAY TO 00 12

YEAR MO DAY

(26-27) (28-29) (30-31) (20-21) (22-23) (24-25) (3 CAM COUNTITY OR LOADING FROM 00

ATTN: JOHN SMITH

T P

FACILITY XYZ W W LOCATION NEWTON

MA 02116

(4 Card Only) QUALITY OR CONCENTRATION

001T рас-мязенимея

(SUBR C) F-FINAL MAJOR

QUARTERLY TOXICITY Data

Form Approved. OMB No. 2040-0004 Approval expires 05-31-98

Check here if No Discharge

NOTE: Read Instructions before completing this form

PARAMETER	2	(3 Card Only) QU	QUANTITY OR LOADING (54-61)	ING	(# Cand Only) O (38-45) O	QUALITY OR CONCENTRATION (48-53) (54-	ENTRATION (54-61)		9×	HEQUENCY OF	SAMPLE
(38-37)		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	100	(84-68)	(02-69)
LC50 STATRE 48HR	SAMPLE	*****	* * * * *		100.08	****	***	(23)	0	06/10	24
acoceriodarhnia EAVlBeat ^o GRoss va	VALREGUREMENT	******	* ****	* * *	100 Dally MN	*****	****	per 3	1	trly	qtrlycomp24
	IR CAMPLE MEASUREMENT	****	****		6.258	***	***	(23)	0	01/90	24
000	VAL REQUIREMENT	*****	* ****	* * *	10 Daily NN	****	****	per-		trly	qtr1ycomp2
	SAMPLE	1									
	PERMIT	1				19-16					
	SAMPLE	. 1									
	PERMIT										
	SAMPLE	-									
	PERMIT	-									
	SAMPLE	1							100		- CO.
	PERMIT				THE SHOP IN	SHARINE.		1000	17		
	SAMPLE	+				211					
	PERMIT									11	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	OFFICER	TWY URDER PERMITY OF LAW TO MAN THE PERMITS OF TAXABLE PERMITS OF TAXA	LA CHAT PERSON DISCHARGE AND ACT THE	ATTACHMENT WENT WITH THE PA	CHARGAST TO			TELEPHONE	3	DA	DATE
JOHN SMITH SUPERINTENDENT	PANT PERSON	The Colour of Deficiency in Entitle Order of the Section of the Se	INC. SCHOOL BALLETS HE INCOME SOF ON PRESENT WHO MAKEET HE STO FOR STHERMS THE INCOME. HE NOW TONE AND BLIEF THE ACCOUNT PICKET TRIVALLES FOR SUBMITTING THE			while	16	9384363		00	10 31
TYPED OR PRINTED	Orms Orms	4 trans AND 30 U.S.C. § 1918	People under Tree statutes	the bullets from the		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	ZED AGENT	ANILA NUMBER	65	YEAR	MO DAY

PAGE

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (MPGES)
DISCHARGE MONITORING REPORT (DMR)
R-16. TO 00 12 31 MONITORING PERIOD (4 Card Only) (38-46) MINIMUM (20-21) (22-23) (24-25) VEAR MO DAY 00 10 01 PERMIT NUMBER MADIDODDE UNITS ** ** 长米式水 SUPERINTENDENT DPW (20-21) (22 MAXIMUM 在我在在在我 **** *** **** **** **** FROM AVERAGE 我我就我我 ***** **** 我我我我我在 我在在本本在 **** (3 Card Only) (46-53) PERMITTEE NAME/ADDRESS (Include Facility Name/Location If Different) PERUITEMENT SAMPLE MEASUREMENT SAMPLE MEASUREMENT PERMIT WEIGHT SAMPLE PERMIT REQUEREMENT SAMPLE SAMPLE MEASUREMENT SAMPLE SAMPLE WEASUREMENT PERMIT PERMIT PERMIT MA 02116 STREET 02116 WEIGHT WEIGHT ADDRESS 123 CENTER MA I P JOHN SMITH XYZ W W T PARAMETER (32-37) FACILITY XYZ W W NEWTON CHROMIUM DRY ARSENIC DRY LOCATION/EWTON 0 0 0 DRY 0 0 7.8473 +10 + + NICKEL SLUDGE SLUDGE STILDGE 01003 8469 THE P

OTRIT GRAB

GR

01/90

0

SAMPLE

HEQUENCY OF ANALYSIS (64-68)

ŠŽŽ ŠŽ

STIND

MAXIMUM

AVERAGE

QUALITY OR CONCENTRATION (48-53) (54-61)

(28-27) (28-29) (30-31

NOTE: Read Instructions before completing this form

DCheck here if No Discharge

FT FINAL

(SUBR C)

SL1 A

NAME

SLUDGE

7-H

ATTACHMENT

(69-70)

GR

GRAB

OTRLY

01/90

0

GRAB

OTRLY

NUMBER (69) TELEPHONE 4567 MG/KG G/KG IG/KG (69) IG/KG MG/KG 4G/KG (69) 978,123 AREA DATEV MY ATT.Y MX REPORT REPORT REPORT DAILE 29.5 5.0 0.2 ASIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 2 **** 我我我我我我 **** **** **** ****** **** 水水水水水水 **** 在在衣衣衣衣 **** **我我我我我**

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SLUDGE TAKEN TO POTW FOR SURFACE DISPOSAL

TYPED OR PRINTED

EXECUTIVE OFFICER AND ADDRESS OF A SECRET AND ADDRESS

PERMIT REQUIREMENT

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

SMITH,

JOHN

PAGE

DAY

OW

YEAR 00

31

DATE

ATTACHMENT C FREQUENCY OF ANALYSIS CODES

·····	NOT APPLIC NOT REPORTD NOT VALID ALL EVENTS ALTERNTRUN BI- WEEKLY CHLRNTN/OCCURS DLY WHNDISCHRG ESTI- MATE LIFE/ PERMIT MEA- SURED MONTHLYWHN DIS NOT REPORTD REPORT WHEN DISCHRG MEASRD WHN MON ONCE/ BATCH ONCE/ DSCHDY ONCE/ DSCHDY ONCE/ DSCHQTR ONCE/ DSCHQTR ONCE/ DSCHQTR ONCE/ DSCHQTR ONCE/ DSCHWK ONCE/ DSCHWK ONCE/ DSCHWK ONCE/ DSCHWK ONCE/ DSCHWT ONCE/ RPT PER ONCE/ SHIFT ONCE/ SEASON ANNUAL DAILY ONCE/ 2 DAYS ONCE/ 3 DAYS ONCE/ 5 DAYS ONCE/ 5 DAYS		
N/A	NOT APPLIC	03/01	THREE/ DAY
N/R	NOT REPORTD	03/05	THREE/ 5 DAYS
N / W	NOT TALL	03/07	THREE/ WEEK
7 7 7 7 7 7 7	NOI VALID	03/08	THREE / 8 DAYS
HL/LV	ALL EVENIS	03/30	TUDEE / MONTU
AL/RN	ALTERNTRUN	03/30	INCE/ MONIN
BI/WK	BI- WEEKLY	03/51	THREE/ 5 ILAKS
: CL/OC	CHLRNTN/OCCURS	03/6M	THREE/ 6MONTHS
DI/DS	DLY WHNDISCHRG	03/90	THREE/ QUARTER
ESTMT	ESTI- MATE	03/99	SEE PERMIT
1 F / DT	TTEE/ DEDMIT	04/BA	FOUR / BATCH
LF/FI	TILE/ LEVAII	01/BH	FOUR / RDT DFR
MEASD	MEA- SURED	04/10	FOID / VEND
MM/WD	MONTHLYWHN DIS	04/IR	FOUR/ ILAK
N/R	NOT REPORTD	04/01	FOUR/ DAY
REPRT	REPORT	04/07	FOUR/ WEEK
WH/DS	WHEN DISCHRG	04/30	FOUR/ MONTH
WH/MN	MEASRD WHN MON	04/90	4 TIMES/ORTLY
01/BA	ONCE / BATCH	04/99	SEE PERMIT
01/DD	ONCE / DECUDY	05/BA	FIVE/ BATCH
01/00	ONCE/ DSCHDI	05/DM	5 DAVC/MEEK
OI/DM	ONCE/ DSCHMN	05/DW	5 DAIS/WEEK
01/DQ	ONCE/ DSCHQTR	05/WK	5 TIMES/WEEK
1 01/DS	ONCE/ DISCHG	05/01	5 TIMES/DAY
01/DW	ONCE/ DSCHWK	05/07	WEEK- DAYS
01/HV	ONCE/ HARVEST	05/08	FIVE/ 8 DAYS
01/00	ONCE / OCCURNO	05/30	5 TIMES/MONTH
01/00	ONCE \ DN EINE	05/90	FIVE/ ORTLY
U1/KN	ONCE / KN EVNT	05/00	CLL DEDWIL
UI/RP	ONCE/ RPT PER	0.5 / 3.3	CIV/ODDCHIES
01/SH	ONCE/ SHIFT	U6/SH	SIX/OPKSHIFT
: 01/SN	ONCE/ SEASON	06/01	SIX/ DAY
01/YR	ANNUAL	06/07	SIX/ WEEK
01/01	DATLY	06/30	6 TIMES/MONTH
01/01	ONCE / 2 DAVC	06/90	SIX/ ORTLY
01/02	ONCE/ 2 DAIS	06/99	CEE DEDMIT
01/03	ONCE/ 3 DAYS ONCE/ 4 DAYS	00/99	SEE PERMIT WEEKLY WHN DIS 7 TIMES/WEEK 7 PER 2 WEEKS 7 TIMES/MONTH SEE PERMIT EIGHT/ BATCH EIGHT/ DAY EIGHT/ MONTH SEE PERMIT NINE/ DAY NINE/ MONTH SEE PERMIT TEN/ MONTH SEE PERMIT TEN/ MONTH
01/04	ONCE/ 4 DAYS ONCE/ 5 DAYS	0 7 / W D	WEEKLI WHN DIS
01/05	ONCE/ 5 DAYS	07/WK	/ TIMES/WEEK
01/06	ONCE/ 6 DAYS	07/14	7 PER 2 WEEKS
01/07	WEEKLY	07/30	7 TIMES/MONTH
01/08	WEEKLY ONCE/ 8 DAYS	07/99	SEE PERMIT
	ONCE/ O DAYS	08/84	FIGHT/ BATCH
01/09	ONCE/ 9 DAYS	00/DA	ETCHE/ DAY
01/10	ONCE/ 10 DAYS	00/01	EIGHI/ DAI
01/11	ONCE/ 11 DAYS	08/30	EIGHT/ MONTH
01/12	ONCE/ 12 DAYS	08/99	SEE PERMIT
01/13	ONCE/ 13 DAYS	09/01	NINE/ DAY
01/14	ONCE/ 2WEEKS	09/30	NINE/ MONTH
01/2Y	ONCE/ 2 YEARS	09/99	SEE PERMIT
	ONCE/ 2 HERE	10/30	TEN / MONTH
01/21	ONCE/ 3 WEEKS	10/30	CEE DEDMIN
01/28	ONCE/ 4WEEKS	10/99	SEE FERMII
01/30	ONCE/ MONTH	11/30	ELEVEN/MONTH
01/4M	ONCE/ 4 MONTH	12/01	TWELVE/DAY
01/5M	ONCE/ 5MONTHS	12/30	12 PER MONTH
01/5Y	ONCE/ 5 YEARS	13/30	THIRTN/MONTH
01/6M	ONCE/ 6MONTHS	14/30	FOURTN/MONTH
01/60	ONCE/ 2MONTH	15/30	FIFTEEN/MONTH
		16/01	SIXTEEN/DAY
01/7M	ONCE / 7MONTHS	16/30	16 PER MONTH
01/8H	ONCE/ 8 HOURS	17/30	CEMNAN \WONAn
01/90	QTRLY	1 / / J U	
01/99	INSTNT	T 8 \ O T	LIGHTEN/DAY
02/BA	TWICE/ BATCH	18/30	EIGHTEN/MONTH
02/DA	2 DAYS/WEEK	19/30	NINETN/MONTH
02/DD	TWICE/ DRWDOWN	20/30	TWENTY/MONTH
02/DS	TWICE/ DISCH	21/30	TWTYONE/MONTH
	TMICE / DGCRMA	22/30	TWTYTWO/MONTH
02/DW	TWICE/ DSCHWK	23/30	TMTVTHR /MONTH
02/RP	TWICE/ RPT PER	24/01	TWITIHM, MONTH
02/SH	TWICE/ SHIFT	Z4/U1	HOURLY
02/YR			
02/01	TWICE/ DAY	25/30	TWTYFIV/MONTH
02/07	TWICE/ WEEK	26/30	TWTYSIX/MONTH
02/12	TWICE/ 12 DAYS	27/30	TWTYSVN/MONTH
02/30	TWICE/ MONTH	28/30	TWTYEGT/MONTH
		29/30	TWTYNIN/MONTH
02/90	TWICE QTRLY	48/01	EVERY 1/2 HR
02/99	SEE PERMIT		
03/BA	THREE/ BATCH	66/66	WPC PLAN
03/DS	THREE/ DISCHG	77/77	CONTIN-GENT
03/DW	3 DAYS/WEEK	88/88	CLEAN- ING
03/RP	THREE/ RPT PER	99/99	CONTIN-UOUS
03/KI 03/YR	THREE/ YEAR		
	_ 111\ / 111\		

CODES that are printed on your DMR in place of the DMR COLUMN HEADERS [printed beneath permit parameter limit]

```
ALLWLOADALLOWED LOAD
ANNL AVGANNUAL AVERAGE
ANNL MAXANNUAL MAXIMUM
ANNL TOTANNUAL TOTAL
ARI MEANARITHMETIC MEAN
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    ROLL AVGROLLING AVERAGE
    ANNL AVGANNUAL AVERAGE
ANNL AVGANNUAL AVERAGE
ANNL AVGANNUAL AVERAGE
ANNL MAXANNUAL MAXIMUM
ANNL TOTANNUAL TOTAL
ARI MEANARITHMETIC MEAN
AVERAGE AVERAGE
AV AVERAGE BELOW DETECTABLE
AV VALUEAVERAGE VALUE
AN MS LDANNUAL MASS LOADING
DA GEOADDAILY GEOMETRIC AVERAGE
DAILY AVDAILY AVERAGE
DAILY MADAILY MINIMUM
DLYAVMINDAILY AVERAGE MINIMUM
DLYAVMINDAILY AVERAGE MINIMUM
DLYAVMINDAILY AVERAGE MINIMUM
DLYAVMINDAILY AVERAGE DAY GEOMET.
DPD AVG DISCHARGE PER DAY AVERAGE
DPD GEO DISCHARGE PER DAY MAXIMUM
DPD MIN DISCHARGE PER DAY MAXIMUM
DPD MIN DISCHARGE PER DAY MAXIMUM
DPD MIN DISCHARGE PER DAY MAXIMUM
DPD TOT DISCHARGE PER DAY MAXIMUM
DPD TOT DISCHARGE PER DAY MAXIMUM
DPD TOT DISCHARGE PER DAY TOTAL
WKLY AVGWEEKLY AVERAGE
UNIT MINIMUM
DRAW GEOMMERKLY GEOMETRIC
DISCHARGDISCHARGE
DE O ALLY GEOMETRIC
DISCHARGED EXPLOYERS
DAY MEAN
HIN REPORTED MINIMUM
SPIT MIN REPORTED MINIMUM
AVERAGE
ART MIN REPORTED MINIMUM
AVERAGE NO COLLING AVE
AGGROLAVAGGRV 12 MO ROLLING AVE
AGGROLAVAGGRV 12 MO ROLLING
AVERAGE
SINGSAMPSINGLE SAMPLE
SMZCNSAMSINGLE WV CONC. SAMPLE
SMZCNSAMS
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        RPT AVG REPORTED AVERAGE RPT MIN REPORTED MINIMUM
           LBS/EVNTPOUNDS PER EVENT
MAX BDL MAXIMUM BDL

MAXIMUM MAXIMUM BDL

MAXIMUM MAXIMUM BDL

MEAN
MEAN
MEAN
MEDIAN
MEDIAN
MEDIAN
MEDIAN
MEDIAN
MEDIAN
MEDIAN
MEDIAN
MEDIAN
MEROPIAN
MEDIAN
MEDIA
                                   QTRTOTALQUARTERLY TOTAL
```

ATTACHMENT C-1

ATTACHMENT D

SAMPLE TYPES

[or]		[or]	
CA	CALCTD	RF	RCDFLO
CG	CMPGRB	RG	RANG-C
CN	CONTIN	RP	REPRES
CP	COMPOS	RT	RCOTOT
CR	CK REQ	R4	RNG-4A
CS	CORSAM	SB	SQBCHR
CT	CERTIF	SE	SNGLES
CU	CURVE	SM	SUMATN
DA	DAILAV	SR	SGLRDG
DS	DISCRT	SS	STAT-SH
ES	ESTIMA	ST	STATIC
FI	FLOIND	TI	TIMEMT
GH	5GR24H	TM	TOTALZ
GM	GRAB10	VI	VISUAL
GR	GRAB	01	COMP-1
G2	GRAB-2	02	COMP-2
G3	GRAB-3	03	COMP-3
G4	GRAB-4	04	COMP-4
G5	GRAB-5	05	COMP-5
G6	GRAB-6	06	COMP-6
G7	GRAB-7	08	COMP-8
G8	GRAB-8	1H	AVG-1H
G9	GRAB-9	10	COMP10
IM	IMERSN	12	COMP12
IN	INSTAN	16	COMP16
IS	INSITU	2H	AVG-2H
IT	IMRSTB	20	COMP20
MC	MATHCL	22	BATCH
MP	MATHCP	24	COMP24
MS	MEASRD	28	COMP28
MT	METER	3G	3GR/HR
NA	NOT AP	4 C	4DA24C
NR	NOTRPT	4 H	AVG-4H
OC	OCCURS	5G	5GR45M
PC	PMPCRV	72	COMP72
PL	PMPLOG	96	COMP96
RC	RCORDR		
RD	RNG-DA		

11/12/03

180 UNIT CODES

#TABLE-CD				#TABLE-DESC
01	KG/	DAY	KG/DAY	KILOGRAMS PER DAY MILLION GALLONS PER DAY
03		MGD	MGD	MILLION GALLONS PER DAY
05	MBTU/	HR	MBTU/HR	MILLION BTU'S PER HOUR
06	MBTU/	DAY	MBTU/DAY	MILLION BTU'S PER HOUR MILLION BTU'S PER DAY
07		GPD	GPD	GALLONS PER DAY
08		CFS	CFS	CUBIC FEET PER SECOND
09 1C	NUMBE	JTU P/MT	MIIMDED /W	JACKSON TURBIDITY(CANDLE) UNIT LNUMBER PER MILLILITER
1G	MOMPE	BTU	NUMBER/M BTU	BRITISH THERMAL UNITS
1L	UG/KG	БІО	UG/KG	MICROGRAMS PER KILOGRAM
1P	FIBER			LFIBERS/MILLILITER
1R				GPOUNDS / 1000 GALLONS
1U	RATIO		RATIO	RATIO
1W	KG/	MONTH		KILOGRAMS PER MONTH
1X	GALLO	N/HOUR	GALLON/H	RGALLONS PER HOUR
10		PT-CO	PT-CO	COLOR - PLATINUM COBALT UNIT STANDARD UNITS (I.E. PH)
12		SU	SU	STANDARD UNITS (I.E. PH)
13	#/	100ML	#/100ML	NUMBER PER 100 MILLILITERS
15		DEG.F	DEG.F	DEGREES FAHRENHEIT MILLIGRAMS PER LITER
19	MODT /	MG/L	MG/L	MILLIGRAMS PER LITER
2A 20	MGAL/	YK DDM	MGAL/IK	MILLION GALLONS PER YEAR
21		DDB	DDD	PARTS PER MILLION PARTS PER BILLION PARTS PER TRILLION
22		PPT	PPT	PARTS PER TRILLION
23	PER-	CENT	PERCENT	PERCENT
25		ML/L	ML/L	PERCENT MILLILITERS PER LITER
26		LBS/D	YLBS/DAY	POUNDS PER DAY
28		UG/L	UG/L	MICROGRAMS PER LITER
29		PSI	PSI	POUNDS PER DAY MICROGRAMS PER LITER POUNDS PER SQUARE INCH MILLION GALLONS
3R		MGAL	MGAL	MILLION GALLONS
3Z	CFU/	TOOML	CEO/IOOM	LCOLONY FORMING UNITS PER 100ML
30	MPN/			LMOST PROBABLE NUMBER PER 100ML
31 32	THRES	HNOWRE	RTHRESHNU	MTHRESHOLD NUMBER
32	BTU/	DOLLD PLIU	בייון/טס בייוו/טס	PARTS PER THOUSAND BTU'S PER HOUR
34	BTU/	DAY	BTU/IIK	BTU S FER HOOK
35	GR/	DAY	GR/DAY	BTU'S PER DAY GRAMS PER DAY
36	GR/L	<i>D</i> 111	GRAMS/L	GRAMS PER LITER
37	J-1, _	KG/L	KG/L	KILOGRAMS PER LITER
4A	METRI	CTON/Y	RMTPY	KILOGRAMS PER LITER METRIC TONS PER YEAR
4B	METRI	CTON/H	AMT/HECTA	RMETRIC TONS PER HECTARE
4C				MOST PROBABLE NUMBER PER GRAM
4K				N# OF DISCHARGES PER MONTH
4L				ODILUTION RATIO
4M	GRAMS,	/GRAM	GRAMS/GR	MGRAMS PER GRAMS
4R	MEQ/L			RMILLIEQUIVALENTS PER LITER
4S 4T	MW/ MWS/	CM2	MW/CMZ	MILLIWATTS/SQUARE CENTIMETER MILLIWATT-SECONDS PER SQ CENT
4U		CM2	ITWS/CM2	MICROWATT-SECONDS PER SQ CENT
4W	LITTED	S/DAV	LITERS /D	YLITERS PER DAY
4X				SNUMBER OF EXCEEDANCES
4Y				SNUMBER PER 100 LITERS
4 Z	NUMBE			NUMBER OF BATCHES
42	LBS/	TONP		POUNDS PER TON OF PRODUCTION
43	-	NTU	NTU	NEPHELOMETRIC TURBIDITY UNITS
48	MGD/			FMGD PER CFS OF STREAMFLOW/DAY
49	LBS/			FLBS PER CFS OF STREAMFLOW/DAY
5 A		DAY	DAY	DAY

180 UNIT CODES

#TABLE-CD			#TABLE-DESC
5B	MIN/ DAY	MTN/DAY	MINUTES PER DAY
5C			HMILLION GALLONS PER BATCH
5D	•	TONS	TONS
5E	BBTU/DAY	BBTII/DAV	BILLION BTUS PER DAY
5 F			RTONS PER YEAR
5G	MILLI-VOLTS		
5H			TONS PER MONTH
5H 5I	TONS/ MONTH		
5J			MCOLONIES PER GRAM
5L		NUMBER	NUMBER
-			MILLIGRAMS PER MONTH
5P	# /DTCCDAY	MILIMPED	NANOGRAMS PER KILOGRAMS NUMBER OF DISCHARGES PER DAY
5Q	#/DISCDAY	NUMBER LB/YR KG/YR	NUMBER OF DISCHARGES PER DAI
50 51	LB/IK	LB/IK	POUNDS PER YEAR
51			
52			KILOGRAMS PER BATCH
53		GPB	GALLONS PER BATCH
54			SMEGAWATTS
55		SPOUNDS	
56		KG	KILOGRAMS
57	GAL	GAL	GALLONS
58	1000 CF	1000CF	1000 CUBIC FEET
59			POUNDS PER WEEK
6C		MLBS	MILLION POUNDS
6D	MICKO-POUNDS	MICKO-TR	SMICRO-POUNDS
6E	CUBIC FEET	COBIC FI	MICHO POUNDO DED DAY
6J			MICRO POUNDS PER DAY
64 66	LB/ BATCH	GRAMS/ML	GRAMS PER MILLILETER POUNDS PER BATCH
67		G/ML	GRAMS PER MILLILITER
68		PCI/MG	PICOCURIES PER MILLIGRAM
69		MG/KG	MILLIGRAMS PER KILOGRAM
70			DRY TONS
71			MILLION POUNDS PER YEAR
72			TMILLIGRAMS PER SQUARE METER
73			STOXICITY UNITS
75	UC/ML		MICROCURIES PER MILLILITER
76	LB/MON	ILBS/MONT	HPOUNDS PER MONTH
77	MG/ CUBMSF	MG/CUBMS	FMG/DAY PER CU METER-STREAMFLOW
78		GPM	GALLONS PER MINUTE
79	HOURS/DAY	HOURS/DA	YHOURS PER DAY
8A	HOURS	HOURS	HOURS
8D	GAL/MC	GAL/MONT	HGALLONS PER MONTH
8E	GAL/YR	GAL/YEAR	GALLONS PER YEAR
8F	MGAL/ YEAR	MGAL/YEA	RMILLION GALLONS PER YEAR
8G			GALLONS PER WEEK
81	MGAL/ QTR	MGAL/QTR	MILLION GALLONS PER QUARTER
8K			SECONDS
80			MILLION GALLONS PER MONTH
81			HOURS PER WEEK
82	HOURS/MONTH	HRS/MONT	HHOURS PER MONTH
83	DAYS/ WEEK	DAYS/WEE	KDAYS PER WEEK
84	DAYS/ MONTH	DAYS/MON	DAYS PER MONTH
85			CUBIC FEET PER DAY
88			YOCCURRENCES PER DAY
89			OCCURRENCES PER WEEK
9C			OCCURENCES PER YEAR
9D			EPOPULATION SERVED
9E			ROCCURRENCES PER QUARTER
90			APOUNDS PER 1000 GALLONS
93	OCCUR/MONTH	OCC/MONT	HOCCURRENCES PER MONTH

ATTACHMENT E

No Data Indicator Code (NODI)

CODE	DESCRIPTION
A	GENERAL PERMIT EXEMPTION
С	NO DISCHARGE
D	LOST SAMPLE
E	ANALYSIS NOT CONDUCTED
F	INSUFFICIENT FLOW FOR SAMPLING
G	SAMPLING EQUIPMENT FAILURE
Н	INVALID TEST
I	LAND APPLIED WASTE WATER
J	RECYCLED, WATER-CLOSED SYSTEM
K	FLOOD DISASTER
L	DMR RECEIVED BUT NOT ENTERED
M	NOT APPLICABLE DURING SLUDGE MONITOR PERIOD
N	NOT TRACKED IN PCS FOR THIS PERIOD
Q	NOT QUANTIFIABLE
R	ADMINISTRATIVELY RESOLVED
1	WRONG FLOW
2	OPERATIONS SHUTDOWN
3	LOW LEVEL PRODUCTION
4	LAGOON PROCESSING
5	FROZEN CONDITIONS
6	PRODUCTION BASED LIMITS DON'T APPLY TO MONITORING PERIOD
7	DMR RECEIVED, PRODUCTION OR FLOW RELATED
8	OTHER
9	MONITORING IS CONDITIONAL/NOT REQUIRED THIS MONITORING PERIOD

If you use a NODI code, do not enter values for Frequency of Analysis nor for Sample Type. Enter the NODI anywhere on the applicable parameter line, circled. Or, if a NODI is for an entire outfall, enter in the box on the top right of the DMR. Submit an explanation when using a NODI Code. NODI codes L, N, R, and 8 are for US EPA and State use only.

ATTACHMENT F

TOXICITY TEST SUMMARY SHEET

Facility Name:		Test Start Date: Pipe Number:		
NPDES Permit Number	·;			
Test Type Acute Chronic Modified (Chronic Reporting acute Values) 24 Hour Screening	Test Species Fathead Minnow Ceriodaphnia Daphnia Pulex Mysid Shrimp Sheepshead Menidia Sea Urchin Champia Selenastrum Other	Sample Type Prechlorinated Dechlorinated Chlorine Spiked in Lab Chlorinated On Site Unchlorinated	· · · · · · · · · · · · · · · · · · ·	
Dilution Water				
	ter collected at a point	upstream of or away fr	om the discharge, free from	
	other sources of contami	-	o o a_ooa_go,ooo	
-	lving water name:			
alternate su	rface water of known qua	/ ulity and a hardness et	c. to generally reflect the	
	ics of the receiving wat		e. to generally refrect the	
	ace water name:			
			quivalent de-ionized water	
-	= =	=	=	
	grade chemicals; or deid		ch mineral water;	
	l sea salts mixed with d			
	ter and hyper saline bri			
other				
Effluent Sampling d	late (s):			
Effluent concentrat	ions tested (in %):			
	imit concentration):			
"(Permit I	IMIC Concentration).			
Was effluent salini	ty adjusted?			
If yes, to what val	•			
	Hypersaline brine	solution?		
	centrations tested after	r salinity adjustment		
Reference Toxicant	test date:			

(CONTINUED OPPOSITE SIDE)

ATTACHMENT F (Cont.)

PERMIT LIMITS & TEST RESULTS

Test Acceptability criteria

CONTROL CONTROL	SURVIVAL:	MEAN CONTROL O	
	Limits		Results
LC50		LC50 UPPER VALUE LOWER VALUE DATA ANALYSIS METHOD USED	
A-NOEC		A-NOEC	
C-NOEC		C-NOEC	
		LOEC	
IC25		IC25	
IC50		IC50	

ATTACHMENT G

NPDES Whole Effluent Toxicity Testing, Monitoring and Reporting Tips, Common Pitfalls and Guidance

EPA-New England's review of Whole Effluent Toxicity ("WET") test data has revealed numerous inconsistencies between the test protocols and the reports submitted by National Pollutant Discharge Elimination System ("NPDES") permittees and their analytical laboratories. This document is part of the 2003 DMR Instructions, available in hard copy from EPA and also posted at Web address www.epa.gov/region01/compliance/enfdmr.html. It was prepared for NPDES permittees: (1) to remind you of NPDES reporting requirements, including the requirement to sign and certify WET reports submitted to EPA and the State; (2) to alert you of common errors detected by EPA in testing and reporting; (3) to provide guidance; and (4) to provide a list of EPA personnel available to answer your questions.

TIPS:

1. NPDES Permit Requirements

The sampling location, sample type, test frequency, test species, monitoring period, and reporting requirements are specified in Part I (and ATTACHMENTs) of the NPDES permit. Read your Permit carefully. Permittees and analytical laboratories must adhere to permit requirements and tests protocols. Ultimately the permittee is responsible for data quality, data integrity and NPDES reporting. EPA recommends that you provide your testing laboratory with a copy of your entire NPDES permit (i.e. Part I and ATTACHMENTs, and Part II "General Conditions") and any subsequent modifications together with any alternate dilution water authorization letters. Mistakes have been made that could have been avoided if the bioassay laboratory had had a copy of these documents.

2. WET Tests Data Quality and Reporting

Carefully review bioassay tests results and be sure that the data are valid (i.e. the minimum test requirements and test acceptability criteria are met for EPA's standard and EPA - New England Region specific protocol) and are correctly reported on the DMR.

3. WET Test Scheduling

Laboratories have scheduled WET tests using test organisms that are at or near the oldest acceptable age for test start. If this is done and there is a delay in sample delivery, the test organisms may be too old for use in the bioassay test when the sample arrives. This could create some scheduling difficulties or could require a contingency plan that includes a secondary emergency source of test organisms. It is suggested that permittees ask whether laboratories have contingency plans for such situations.

4. Methods Manuals

The most current methods manuals are as follows:

- a. Weber, C.I. et al., <u>Methods for Measuring the Acute Toxicity of Effluents to Freshwater and Marine Organisms</u>, Fourth Edition, August 1993, EPA/600/4-90/027F;
- b. Lewis, P.A. et al., <u>Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Water to Freshwater</u> Organisms, Third Edition, July 1994, EPA/600/4-91/002;

- c. Klemm, D.J. et al., <u>Short Term Methods for Estimating Chronic Toxicity of Effluents and Receiving Water to Marine and Estuarine Organisms</u>, Second Edition, EPA/600/4-91/003; and
- d. <u>Standard Methods for the Examination of Water and Wastewater</u>, 20th Edition, 1998.

COMMON PITFALLS AND GUIDANCE:

To alert you to the common pitfalls and provide guidance to rectify issues where present, the following provides guidance on the use of alternate dilution as well as a summary of the most common errors detected in testing and reporting:

1. WET Monitoring and Reporting

EPA rejects toxicity test reports that do not follow permit requirements, applicable protocols, and meet <u>all</u> minimum criteria for acceptability of test results, and requires tests to be repeated until valid results are obtained. Valid results must be submitted by the date specified in Part I of the NPDES permit even if the test has to be repeated. Therefore, EPA recommends that sampling and testing be initiated early in the monitoring period prescribed by the permit.

If a valid test is not completed by the reporting deadline, the permittee must report the invalid test using the proper code on the DMR; the code is "H". The cover letter must explain the monitoring and reporting violation and state when the test will be repeated. A corrected DMR must be resubmitted once valid data are available, and the entire report submitted as required by the permit. The report shall include, among other things, bench sheets to document that there was an invalid test and the test was repeated.

2. Sample Dechlorination

The total residual chlorine concentration of the effluent sample shall be measured and, if detected, the sample shall be dechlorinated in the laboratory prior to WET testing in accordance with Standard Methods for the Examination of Water and Wastewater, $20^{\rm th}$ Edition, 1998. The concentration should be reported and the dechlorination method described. The dechlorination method used at the bioassay lab has not always been described in WET reports. For example, dechlorination can be achieved using a ratio of 6.7 mg/L anhydrous sodium thiosulfate to reduce 1.0 mg/L chlorine. An additional thiosulfate control (with the maximum amount of thiosulfate in the lab control or the receiving water control) <u>must</u> also be run if dechlorination is performed. This information must also be included in the report.

3. Sample Hold Time

Sample hold time was exceeded at the onset of the test. Sample hold time must be consistent with that specified by test protocol, namely, less than 24 hours old for on-site tests and less than 36 hours old for off-site tests, as specified in the updated protocols. In isolated cases where the test cannot be started within 36 hours of sample collection, data must be submitted to EPA and the State to demonstrate that the effluent toxicity of a sample is not reduced by extending the holding time beyond 36 hours.

4. Salinity Adjustment of the Effluent Sample

When brine solution is used to adjust the salinity of the effluent sample for marine WET testing, it reduces the highest effluent concentration tested to between 70% and 80% effluent. If the Chronic No Observed Effects Concentration ("C-NOEC") limit of the Permit is 100% (as is the case when an outfall is exposed at low tide), sea salts must

be used to adjust salinity so that compliance testing can be done at the 100% effluent concentration. It should be noted that the Region's revised test protocols require the use of sea salts for salinity adjustment in every case; previous protocols allowed the permittee to choose between using brine solution and sea salts.

5. Age of the Test Organisms

Tests have been performed using organisms that were older than the age specified by the tests protocol. WET tests are to be conducted during sensitive life stages of the test organism. For that reason, the protocols specify what the age of the test organism must be at test initiation. Evidence of test organism age must be reported.

6. Raw Data and Bench Sheets

Raw data and bench sheets were not submitted as required by the permit. These data must be included in the full report.

7. Report Integrity and DMR Accuracy

 $\overline{\text{WET}}$ test data summary tables have not always been consistent with the report text, data analyses, bench sheets; and/or DMRs. Report integrity and DMR accuracy are crucial, and are the responsibility of the permittee.

8. Data Analyses

Inappropriate statistical methods were used on bioassay data sets. Flow charts in the EPA Acute and Chronic WET Test Manuals must be followed so that the correct analyses are performed. Statistical program printouts and graphical displays (LC50 calculations, etc.) are not always submitted. The testing laboratory should make use of the available statistical software to perform the data analyses as described in the protocols attached to the NPDES permit, and must include the printouts with every report. In addition, please be aware that certain statistical programs require a minimum number of replicates which does not necessarily match the minimum number required in the EPA test guidance manual but has been accounted for under EPA - New England Region protocols.

9. Chronic Ceriodaphnia dubia Survival and Reproduction Test Duration

The duration of the chronic <u>Ceriodaphnia</u> <u>dubia</u> survival and reproduction test must not exceed eight days. The minimum acceptability criteria for this test as measured in both the laboratory and the dilution water controls are: (1) 80% or greater survival in the control population; (2) an average of 15 or more young/female in the control population; and (3) at least 60% of the surviving females in the control population shall have produced a third brood. Typically, the third brood is produced by day 7. If this does not happen by the end of **day 8**, it may indicate that the test conditions (i.e., temperature) and/or nutrition (i.e., food) were inadequate or the test organisms themselves were of poor quality. The test is invalid and <u>must</u> be repeated. (Reference EPA/600/4-91/002, July 1994, p. 144.)

10. Document Ongoing Laboratory Performance

The reference toxicant data have not always been submitted with the report. As part of an in-house Quality Assurance Program, each laboratory must perform reference toxicant tests on the test organisms it uses and analyze data for the reported test endpoints. Reference toxicant testing must be done monthly in accordance with the EPA Methods Manuals (e.g. EPA/600/4-91/002, Third Edition, July 1994, Section 4.16.1, p. 16). An updated endpoint-specific, reference

toxicity test control chart \underline{must} be included in every report. Also, if a reference toxicant test was being performed concurrently with an effluent or receiving water test and fails, \underline{both} tests \underline{must} be repeated.

- 11. Sampling Methods, Holding Times, and Preservation Techniques
 All sampling methods, holding times and preservation techniques must be consistent with 40 CFR Parts 122 and 136. Note that EPA approved test methods require that samples collected for metals analyses be preserved immediately after collection. It has come to EPA's attention that the aliquot for metals testing is sometimes split off and preserved upon arrival at the bioassay laboratory.
- 12. Include an Additional Dilution at the Permitted Effluent Concentration

 The minimum number of effluent concentrations to be tested must include an additional dilution at the permitted effluent concentration. This is not always done by the testing laboratory and is extremely important for compliance monitoring.
- 13. Acclimate the Test Organisms to the Dilution Water

Acclimating the test organisms to the dilution water should be done gradually prior to test start. Test organisms are sensitive to abrupt changes in their environment. These abrupt changes can produce a negative and sometimes fatal response to otherwise healthy organisms. In order to provide useable information on possible receiving water effects to test organisms, adherence to test protocols is necessary. Whatever the possible cause of negative response due solely to receiving water characteristics, it is good laboratory practice to follow proper acclimation procedures to eliminate the question of negative response due to abrupt ambient changes. Depending on the severity of the difference between culture water and test dilution water, acclimation using 1:1 dilutions of culture water to dilution water is recommended over a period of several hours until dilution water characteristics are matched.

14. Dilution Water

The objective of the WET test is to estimate the toxicity of the effluent in uncontaminated receiving water. Ideally, a grab sample of receiving water must be collected upstream and/or outside of the influence of the outfall for use as dilution water in the tests.

EPA-New England has adopted a species-specific, self-implementing policy for switching to an alternate dilution water during the life of the NPDES permit for WET tests where the receiving water is documented to be toxic or unreliable. The policy authorizes alternate dilution water use in two cases: (1) in any WET test repeated due to site water toxicity. No prior notification to EPA is required for any current test that needs to be repeated due to site water toxicity; and (2) in future WET tests where there are two previously documented incidents of site water toxicity associated with a particular test species. Written notification to EPA is required before switching to alternate dilution water testing for the duration of the life of the permit.

The details of EPA-New England's species-specific, self-implementing policy are provided below.

Case (1): EPA - New England authorizes the use of an alternate dilution water for any WET test repeated due to site water toxicity. This authorization is species-specific. If the permittee is required to conduct WET tests using two species, and the receiving water is

toxic or unreliable for only one species, then alternate dilution water use is authorized for that species only.

- (a) The permittee no longer has to *immediately* notify EPA before an invalid WET test is repeated using an alternate dilution water.
- (b) The test must be repeated during the monitoring period specified by the Permit.
- (c) The selected alternate dilution water must have characteristics such as hardness, pH, conductivity, alkalinity, organic carbon, and total suspended solids similar to those of the receiving water, and should not produce a toxic response. Receiving water controls must also be run in alternate dilution water tests.
- (d) A complete WET test report must be submitted by the permittee as required by the Permit. The report must clearly document:
 - (1) that site water toxicity rendered the first test invalid;
 - (2) that a retest was conducted using an alternate dilution water that matched the characteristics of the site water;
 - (3) that site water controls were included in the retest; and
 - (4) whether the site water controls of the retest met the minimum test acceptability criteria.
- (e) If the retest documented that the site water controls met the minimum test acceptability criteria, site water must be used as diluent in future WET tests. If the site water controls of the retest failed to meet test acceptability criteria, an alternate dilution water may be used in future WET tests using that test organism after submitting written notification to EPA. (See Case (2) below.)

(a) Before alternate dilution water testing begins, the permittee must submit to EPA written notification of site water toxicity,
provide supporting data, describe the alternate dilution water
selected, and confirm that the required sets of controls will be
run in future WET tests (e.g., site water controls, lab water
controls, and adjusted lab water controls). This letter shall be
sent to both of the following:

Linda Murphy, Director
Office of Ecosystem Protection (CAA)
U.S. Environmental Protection Agency
One Congress Street, Suite 1100
Boston, MA 02114-2023

Chief Water Technical Unit (SEW) U.S. Environmental Protection Agency One Congress Street, Suite 1100 Boston, MA 02114-2023

(b) At a minimum, EPA will review alternate dilution water authorizations during permit reissuance.

This guidance is intended to promote compliance and enhance program efficiency and effectiveness. This is not intended to, nor does it, constitute rulemaking by EPA and may not be relied upon to create a right or a benefit, substantive or procedural, enforceable at law or in equity, by any person. EPA reserves the right to revoke this guidance at any time and may immediately require the Permittee to use site water

as diluent as EPA deems necessary. Such a determination will be provided in writing to the permittee.

15. Chemical/Physical Analyses of Effluent Sample

The results of the chemical/physical analyses which are to be routinely performed with biomonitoring testing have not always been submitted along with other discharge data required by Part I of the permit. The absence of required data results in an incomplete and unacceptable submission.

16. Non-Linear Dose-Response Relationship

As stipulated in EPA - New England protocol, if test results do not exhibit a linear dose-response relationship (i.e., if two tested concentrations cause statistically significant effects, but an intermediate concentration did not cause statistically significant effects when compared to the control), report the lowest effluent concentration where there is no observable effect. In the past permittees have incorrectly reported the higher value. Although the WET test is valid, the results should be used with caution.

17. Number of Replicates per Concentration

The test sensitivity is affected by the number of replicates run per concentration. Test sensitivity is defined as the probability of identifying toxic effects of discharges. Sometimes false negatives occur because the toxicity was not statistically detected when comparing the control to the test concentrations.

To increase test power, the laboratory can either reduce test variability or increase the number of replicates. EPA - New England has updated the <u>Pimephales promelas</u> test protocols to require four replicates of each effluent concentration. (Earlier protocols gave a minimum of three replicates as an option.) When the data are analyzed by hypothesis testing, the non-parametric statistical tests cannot be used unless there are at least four replicates at each toxicant concentrations. (Reference EPA/600/4-91/002, Third Edition, July 1994, pp. 49, 53.)

18. Missing Test Organisms

Missing organisms have been noted on bench sheets for the <u>Ceriodaphnia dubia</u> survival and reproduction test. This could indicate that there is a lack of familiarity with the laboratory technique and is something that should not happen very often, if at all. If an organism is simply identified as missing , or dead without reason (e.g., due to handling error), it <u>must</u> be treated as a test mortality when performing the statistical analyses of the data or when making a test validity check.

19. Laboratory Performance/Test Organisms Health

In some instances, test organism health was questionable at test start, but the test was run anyway. Within 24 hours, the test controls failed to meet the test acceptability criteria, therefore, the test was invalid and had to be repeated. It is important for a laboratory to have a contingency plan for obtaining healthy organisms from another source within 36 hours of sample collection so that the test is not started with organisms of questionable health. The health of test organisms is crucial to test acceptability and permit compliancemonitoring. As evidence of test organism health as well as acceptable laboratory performance during the testing period, the appropriate reference toxicant control chart is to be included by the laboratory as part of the toxicity test report (refer to the test protocols in your NPDES permit).

20. Site Water Controls in Alternate Dilution Water Tests

Alternate dilution water WET tests shall be run with a minimum of two controls; a site water control and a toxic free alternate dilution water control. A thiosulfate (third) control must also be run, if necessary. (See item 2. above.) Chemical data of the receiving water and dilution water samples <u>must</u> be included in the report. Some common pitfalls when using an alternate dilution water are: (1) the failure to submit the water chemistry (of both the receiving water and the alternate dilutions water) with the reports; (2) the alternate dilution water characteristics were not similar to those of the receiving water; and (3) a receiving water control was not run (i.e., two controls were not run) in the case of an alternate dilution water test. One of Two Controls Did Not Meet the Minimum Test Acceptability Criteria When two controls were run and one did not meet the minimum WET test acceptability criteria (i.e., the test is invalid), laboratories have not always repeated the tests. The only circumstance where a WET test would not have to be repeated, if one of the two controls did not meet the test acceptability criteria, would be a test where all of the dilutions met the minimum test acceptability criteria. The WET test would be considered as conditionally valid, since one control would have demonstrated that the organisms were healthy and the dilutions demonstrated no effluent toxicity.

21. Use of Control Data

The labs sometimes run the statistical analyses comparing the acceptable (lab) control with the dilution series data, and the test data were reported on the DMRs. When performing statistical analyses, the dilution water control is the appropriate one to use for data comparison.

22. Sign and Certify Each WET Report

Under 40 C.F.R. \$122.41(k), each WET test report submitted to the EPA shall be <u>signed and certified</u> by a person described below or by a duly authorized representative of that person in accordance with 40 C.F.R. \$122.22(b)-(d):

- (1) for a corporation, by a responsible corporate officer;
- (2) for a partnership or sole proprietorship, by a general partner or the proprietor, respectively; and
- (3) for a municipality, State, Federal or other public agency, the principal executive officer or ranking elected official.

Although permittees and analytical laboratories must both be familiar with specific NPDES Permit requirements and test protocols, it is the permittee who is ultimately responsible for data quality and integrity that it reports to EPA. When a WET report is signed and certified, it documents that the NPDES permittee is certain that the WET test data submitted are valid, follow applicable protocols and meet the minimum criteria for test results acceptability, and meets the permit requirements for testing and reporting. Please include the following report certification statement of 40 C.F.R. §122.22(d) in every report:

WHOLE EFFLUENT TOXICITY TEST REPORT CERTIFICATION

I certify under penalty of law that this document and all ATTACHMENTS were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons who manage the system, or those persons who manage the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Executed o	n	
	[Date]	[Authorized Signature]
		[Print or Type Name and Title]
		[Print or Type the Permittee's Name]
		[Print or Type the NPDES Permit No.]

Since the WET test and report check is complicated, you may wish to have your WET laboratory certify the validity of the WET test data and report accuracy to you. Suggested language is given below. Please note that this does not relieve the permittee from its responsibility to sign and certify the report under 40 C.F.R. §122.41(k).

WHOLE EFFLUENT TOXICITY TEST REPORT CERTIFICATION

I certify under penalty of law that this document and all ATTACHMENTS were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons who manage the system, or those persons who manage the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Executed	on		
211000000		[Date]	[Authorized Signature]
			[Print or Type Name and Title]
			[Print or Type Name of Bioassay Laboratory

24. Telephone Contacts

If you have questions, please contact Joy Hilton, Water Technical Unit, at (617)918-1877 or David McDonald, Ecosystem Assessment Unit, at (617)918-8609.

ATTACHMENT H

BYPASS OR SEWER OVERFLOW REPORT

DATE OF REPORT:	TIME:
DATE OF INCIDENT:	
NAME OF SYSTEM:	
FACILITY NAME:	
NPDES PERMIT No:	
NAME and TITLE of PERSON REPORTING INCIDENT	:
TELEPHONE No:	ext:
LOCATION OF OVERFLOW:	
RECEIVING WATER:	
INCIDENT DURATION: FROM (date)	TIME:
TO: (date)	TIME:
ESTIMATED TOTAL FLOW:	
TREATMENT PROVIDED:	
CAUSE OF INCIDENT:	
MITIGATION MEASURES TAKEN:	
ADDITIONAL INFORMATION / COMMENTS:	
AGENCY / PERSON REPORTED TO:	
US EPA:	
STATE:	